

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 456/26-27

Dated: 30/09/2026

It is certified that an inspection team headed by Dr. Amresh Verma (Superintendent)

(Name of Officers with designation) from CHC Kaurihar (Name of Department/

Office) inspected the Prayag Public School, Lalgopalganj, Prayagraj (Name & Address of the school)

on 30/09/2026 (date of inspection) and checked the Water Test Report submitted by the

school. It was found that the school has safe and potable drinking water for the students and members of staff of the institution.

It is also certified that the school maintains the hygienic and sanitary condition in the school building and campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with Seal: Amresh Verma 30/09/2026

Name सामुदायिक स्वास्थ्य केंद्र

Designation कोडिहार, प्रयागराज

Name & Address of the Office / Department :

To

.....

.....

(Name & Address of the Institution)

KRy
30/09/2026



कार्यालय जलकल विभाग (मु०)
जलकल विभाग प्रयागराज
पत्र सं० ११४ मु० ज० क० वि०
दिनांक २३/१०/२५

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-10/02

Date: 08.10.2025

DRINKING WATER ANALYSIS REPORT

1	Name & Address	PRAYAG PUBLIC SCHOOL & COLLEGE
2	Sample Collected by	By Party
3	Nature of Sample	DRINKING WATER
4	Date of Sample Collection	04.10.2025
5	Date of Sample Receiving	04.10.2025
6	Date of Analysis Completed	08.10.2025

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	28.3	-	-
4.	Turbidity	NTU	3.17	5	10
5.	Conductivity at 25°C	µmho/cm	696.0	-	-

CHEMICAL PARAMETERS

6.	pH	-	7.0	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	334.0	500	2000
9.	Total Solids	mg/L	334.0	-	-
10.	Total Alkalinity (as CaCO ₃)	mg/L	348.0	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	346.0	200	600
12.	Chlorides (as Cl)	mg/L	121.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	0.2	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	0.96	45.0	100.0
15.	Iron (Fe)	mg/L	0.1	0.3	1.0

BACTERIOLOGICAL PARAMETERS

16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

*Note: The water is suitable for drinking purposes-

Analyst

JE(HQ)

जलकल विभाग
नगर निगम-प्रयागराज

- Note:**
1. The above results are related only to the test performed on the sample.
 2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
 3. Sample will be destroyed in the after fifteen days from the date of reporting.